

Date: 26/04/2022

To,
The Director
Regional Office (Central Region)
Ministry of Environment & Forest
5th Floor, Kendriya Bhawan,
Sector H, Aliganj, Lucknow-260224, UP

Subject: Submission of six-monthly Compliance Report for **June 2022** of the Educational Project "Vidyagyan School" at Village-Dulhera, Post Office- Wair, Tehsil- Sikandrabad, District-Bulandshahr, Uttar Pradesh by M/s Slocum Investments (Chennai) Pvt. Ltd.

Reference: (i) MoEF&CC Notification issued vide S.O. 3252 (E), dated 22nd December 2014
(ii) MoEF&CC O.M. F.No. 19-2/2013-IA-III, dated:09th June 2015

Respected Sir,

This is with reference to the above-mentioned subject, we are herewith submitting six monthly Compliance Report of **June 2022** for the period of **October 2021 – March 2022** for the Educational Project "Vidyagyan School" at Village-Dulhera, Post Office- Wair, Tehsil- Sikandrabad, District-Bulandshahr, Uttar Pradesh by M/s Slocum Investments (Chennai) Pvt. Ltd., along with the necessary annexures for your kind perusal.

We understand that the above is in line with requirement of Ministry of Environment & Forest and Climate Change, GOI.

Thanking you,

Yours Sincerely,

For M/s. Slocum Investments (Chennai) Pvt. Ltd.



(Authorized Signatory)



Enclosure: Compliance Report; Soft copy of Report in C.D.

Copy to: 1. Member Secretary, U.P. Pollution Control Board, 3rd Floor,
PICUP Bhawan, Vibhuti Khand, Gomti Nagar, Lucknow (UP) - 226010.
2. Chairman, SEIAA, U.P.



School Administrator
VidyaGyan School
Dulhera, Sikandrabad
Bulandshahr (U.P.)

Meenambika Menon

Principal
VidyaGyan School
Dulhera, Sikandrabad

कार्यालय-प्रभारी चिकित्सा अधिकारी प्रा०स्वा०केन्द्र वैर बादशाहपुर
जिला-बुलन्दशहर (उ०प्र०)

पत्रांक PHC Wair | SCHOOL HYGIENE | 2021-22

दिनांक 28.01.2022

CERTIFICATE

This is to certify that VidyaGyan School, Village- Dulhera, Post- Wair, Tehsil- Sikandrabad, Distt- Bulandshahr (U.P). It's Health and Sanitary condition is satisfactory.

28/01/2022
चिकित्सा अधिकारी
प्रा० स्वा० केन्द्र-वैर
बुलन्दशहर

Meenambika Meena



School Administrator
VidyaGyan School
Dulhera, Sikandrabad
Bulandshahr (U.P.)

Principal
VidyaGyan School
Dulhera, Sikandrabad
Bulandshahr (U.P.)

**“Vidyayan School” located at Dulhera, Bulandshar, Uttar Pradesh by M/s KRN
Educatipon Pvt. Ltd.**

Schedule for STP Outlet monitoring are given in **Table 8**.

Table 8: Schedule for STP Outlet sample collection

Day of sampling	Sample collected on	Locations
Day 1	19/02/2022	STP Plant

Table 8(a): Results of STP Outlet monitoring

S.No	Test Parameters	Units	Results	As Per EP Rules, 1986,Max	Test Method
1	pH	-	7.58	5.5-9.0	IS 3025 (P-11)
2	Oil and grease	mg/l	BDL(DL <2.0)	10	IS 3025 (P-39)
3	Biochemical oxygen demand as BOD at 27 ⁰ C for 3 days	mg/l	8	30	IS 3025 (P-44)
4	Chemical oxygen demand as COD	mg/l	40	250	IS 3025 (P-58)
5	Total suspended solids as TSS	mg/l	26	100	IS 3025 (P-17)

9. Raw Water Monitoring

Schedule for Raw water monitoring is given in **Table 9**.

Table 9: Schedule for water sample collection

Day of sampling	Sample collected on	Location
Day 1	19/02/2022	Nearby Principal Residence

Raw water for Day-1 monitoring results given in **Table 9(a)**.

Table 9(a): - Raw Water Monitoring Results

S. No	Test Parameters	Units	Results	IS 10500 : 2012		Test Method
				Acceptable Limit, max.	Permissible Limit in the Absence of Alternate source, max.	
1	Color	Haze n	BDL (DL-5.0)	5	15	IS 3025 (Pt-04)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Pt-05)
3	pH	-	7.16	6.5-8.5	No relaxation	IS 3025 (Pt-11)
4	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Pt-08)
5	Turbidity	NTU	BDL (DL-1.0)	1	5	IS 3025 (Pt-10)
6	Total Dissolved Solids	mg/l	368	500	2000	IS 3025 (Pt-16)
7	Ammonia (as total ammonia-N)	mg/l	BDL (DL0.5)	0.5	No relaxation	IS 3025 (Pt-34)

**“Vidyayan School” located at Dulhera, Bulandshar, Uttar Pradesh by M/s KRN
Educatipon Pvt. Ltd.**

8	Anionic Detergents (as MBAS)	mg/l	BDL (DL0.1)	0.2	1.0	Annex K of IS 13428
9	Calcium as Ca	mg/l	98.19	75	200	IS 3025 (Pt-40)
10	Chloramines (as Cl ₂)	mg/l	BDL (DL0.1)	4.0	No relaxation	IS 3025 (Pt-26)
11	Chloride as Cl	mg/l	36.2	250	1000	IS 3025 (Pt-32)
12	Fluoride as F	mg/l	0.21	1.0	1.5	APHA 23 rd Ed 4500F
13	Free Residual Chlorine	mg/l	BDL (DL0.05)	0.2	1	IS 3025 (Pt-26)
14	Nitrate as NO ₃	mg/l	1.2	45	No relaxation	IS 3025 (Pt-34)
15	Phenolic Compounds (as C ₆ H ₅ OH)	mg/l	BDL (DL 0.001)	0.001	0.002	IS 3025 (Pt-43)
16	Sulphate as SO ₄	mg/l	26.2	200	400	IS 3025 (Pt-24)
17	Sulphide (as H ₂ S)	mg/l	BDL(DL 0.02)	0.05	No relaxation	IS 3025 (Pt-29)
18	Total Alkalinity as CaCO ₃	mg/l	287	200	600	IS 3025 (Pt-23)
19	Total Hardness as CaCO ₃	mg/l	290	200	600	IS 3025 (Pt-21)
20	Cyanide (as CN)	mg/l	BDL (DL 0.02)	0.05	No relaxation	IS 3025 (Pt-27)
21	Aluminum (as Al)	mg/l	BDL (DL 0.01)	0.03	0.2	APHA 23 rd Ed.3120B
22	Barium (as Ba)	mg/l	BDL (DL 0.1)	0.7	No relaxation	APHA 23 rd Ed.3120B
23	Boron (as B)	mg/l	BDL (DL 0.1)	0.5	1.0	APHA 23 rd Ed.3120B
24	Copper (as Cu)	mg/l	BDL(DL 0.02)	0.05	1.5	APHA 23 rd Ed.3120B
25	Iron as Fe	mg/l	BDL(DL 0.05)	1.0	No relaxation	IS 3025 (Pt-53)
26	Magnesium as Mg	mg/l	10.93	30	100	APHA 23 rd Ed.3500 mg B
27	Manganese as Mn	mg/l	BDL(DL 0.05)	0.1	0.3	APHA 23 rd Ed.3120B
28	Selenium (as Se)	mg/l	BDL(DL 0.01)	0.01	No relaxation	APHA 23 rd Ed.3120B
29	Silver (as Ag)	mg/l	BDL(DL 0.05)	0.1	No relaxation	APHA 23 rd Ed.3120B
30	Zinc (as Zn)	mg/l	BDL(DL 0.05)	5	15	APHA 23 rd Ed.3120B
31	Cadmium (as Cd)	mg/l	BDL(DL 0.001)	0.003	No relaxation	APHA 23 rd Ed.3120B
32	Lead (as Pb)	mg/l	BDL(DL 0.005)	0.01	No relaxation	APHA 23 rd Ed.3120B
33	Mercury (as Hg)	mg/l	BDL(DL0.001)	0.001	No relaxation	APHA 23 rd Ed.3120B
34	Molybdenum (as MO)	mg/l	BDL(DL 0.05)	0.07	No relaxation	APHA 23 rd Ed.3120B
35	Nickel (as Ni)	mg/l	BDL(DL0.01)	0.02	No relaxation	APHA

**“Vidyagyan School” located at Dulhera, Bulandshar, Uttar Pradesh by M/s KRN
Educatipon Pvt. Ltd.**

36	Total Arsenic (as As)	mg/l	BDL(DL 0.01)	0.01	No relaxation	23 rd Ed.3120B APHA 23 rd Ed.3120B
37	Total Chromium (as Cr)	mg/l	BDL(DL 0.03)	0.05	No relaxation	APHA 23 rd Ed.3120B



**School Administrator
VidyaGyan School
Dulhera, Sikandrabad
Bulandshahr (U.P.)**



**Principal
VidyaGyan School
Dulhera, Sikandrabad
Bulandshahr (U.P.)**